



Product Service

CERTIFICATE

No. Z2 18 05 82429 133

Holder of Certificate: **Risen Energy Co.,Ltd**
 Meilin, Ninghai,
 315609 Ningbo, Zhejiang
 PEOPLE'S REPUBLIC OF CHINA



Certification Mark:



Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules
 Mono-Crystalline Silicon Photovoltaic Module**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 704061704311-03

Valid until: 2023-05-15



Date, 2018-05-23

(Zhulin Zhang)

Page 1 of 2



CERTIFICATE
No. Z2 18 05 82429 133

Model(s): RSM72-6-330M, RSM72-6-335M, RSM72-6-340M, RSM72-6-345M, RSM72-6-350M, RSM72-6-355M, RSM72-6-360M, RSM72-6-365M; RSM60-6-275M, RSM60-6-280M, RSM60-6-285M, RSM60-6-290M, RSM60-6-295M, RSM60-6-300M, RSM60-6-305M; RSM144-6-350M, RSM144-6-355M, RSM144-6-360M, RSM144-6-365M, RSM144-6-370M, RSM144-6-375M, RSM144-6-380M; RSM120-6-295M, RSM120-6-300M, RSM120-6-305M, RSM120-6-310M, RSM120-6-315M, RSM120-6-320M;

Parameters:

Rated Output Power at STC:	330 W, 335 W, 340 W, 345 W, 350 W, 355 W, 360 W, 365 W; 275 W, 280 W, 285 W, 290 W, 295 W, 300 W, 305 W; 350 W, 355 W, 360 W, 365 W, 370 W, 375 W, 380 W; 295 W, 300 W, 305 W, 310 W, 315 W, 320 W;
Construction:	Framed, with Junction box, Cable and Connectors.
Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute; No. 10 West Kaifa Road, Yangzhou, 225009 Jiangsu, P. R. China
Safety Class:	Class II
Maximum System Voltage:	1500V DC
Fire Safety Class:	Class C according to UL790

Tested according to: IEC 61215-1(ed.1)
 IEC 61215-1-1(ed.1)
 IEC 61215-2(ed.1)
 IEC 61730-1(ed.2)
 IEC 61730-2(ed.2)

Production Facility(ies): 94163, 82429